

GREEN TOWNSHIP
ADDENDUM TO BID

FIRE ALARM SYSTEM FOR MUNICIPAL BUILDING AND
ASSOCIATED SECURITY SYSTEMS AND SERVICES

ADDENDUM #2

This addendum is issued to clarify, correct or supplement the Documents as originally issued regarding specifications, and will become a part of the Contract. Additionally, the bid opening date has been changed. Receipt of the Addenda shall be acknowledged by Bidders in an Acknowledgement of Receipt of Addendum. Failure to acknowledge this Addendum may be cause for rejection of bid.

1. Exhibit A Addition:

New hardware shall be required with the 10 new full retro-fit magnetic door holders and closers, which hardware shall be compatible with the magnetic holders, as per the manufacturer chosen. The contractor chosen shall submit shop drawings for approval.

2. Exhibit A Addition:

Five (5) heat detectors are required to be provided and installed, as depicted in the plan prepared by O'Brien Architects, Inc. dated July 7, 2016 last revised January 26, 2017 for bidding purposes entitled "Security Alarm Design- Green Township Municipal Building- Floor Plans" (O'Brien Floor Plan), and as required by relevant Code.

2. Exhibit D Clarification:

The door required is as set forth in the New Door Details on the O'Brien Floor Plan, and it is not a fire-rated condition.

3. Exhibit F Clarification:

The existing security system does not need to be replaced unless the proposed fire alarm control panel is not compatible with the existing burglar alarm devices and panics; i.e. the current security system must work with the new fire alarm control panel.

4. Exhibit F Clarification:

The 9 gas detectors to be replaced throughout the building include those located within the HVAC system.

GREEN TOWNSHIP
ADDENDUM TO BID

FIRE ALARM SYSTEM FOR MUNICIPAL BUILDING AND
ASSOCIATED SECURITY SYSTEMS AND SERVICES

ADDENDUM #2

5. Addition

The bid opening date has changed. The bid will now be open on **April 13, 2017 at 11:00 a.m.**

Dated: March 21, 2017



Mark Zschack, Township Administrator